

OPS Pool HVAC Upgrade

Omaha, Nebraska










DESIGNED BY: DRAWN BY: CHECKED BY: – DATE: — 12/29/2023

PROJECT NO: 232051


— SHEET TITLE **COVER SHEET AND INDEX OF DRAWINGS**

G-001


BRYAN HIGH SCHOOL 4700 GILES ROAD, OMAHA, NE 68157



BURKE HIGH SCHOOL 12200 BURKE ST, OMAHA, NE 68154




MCMILLAN MIDDLE SCHOOL 3802 REDICK AVE, OMAHA, NE 68112



\2023\232051\CAD\X-232051_G-001.dwg G-001 12/22/23 4:55pm lmb

MONROE MIDDLE SCHOOL 5105 BEDFORD AVE, OMAHA, NE 68104



MECHANICAL MECHANICAL SYMBOLS LEGEND AND GENERAL NOTES

MECHANICAL DEMOLITION PLANS - BRYAN MECHANICAL DEMOLITION PLANS - BURKE MECHANICAL DEMOLITION PLANS - MCMILLAN

MD131 BASEMENT MECHANICAL DEMOLITION PLANS - MONROE SECOND FLOOR MECHANICAL DEMOLITION PLANS - MONROE

INDEX OF DRAWINGS

COVER SHEET AND INDEX OF DRAWINGS

MCMILLAN PARTIAL BASEMENT PLAN

MONROE PARTIAL TUNNEL PLAN

M - 101MECHANICAL PLANS - BRYAN MECHANICAL PLANS - BURKE M - 111M - 121MECHANICAL PLANS - MCMILLAN

BASMENT MECHANICAL PLANS - MONROE M - 131SECOND FLOOR MECHANICAL PLANS - MONROE M - 132

MECHANICAL SCHEDULES M - 701

ELECTRICAL

COVER SHEET

ARCHITECTURAL


E - 001ELECTRICAL SYMBOLS LEGEND AND GENERAL NOTES


ED121 ELECTRICAL DEMOLITION PLANS - MCMILLAN BASEMENT ELECTRICAL DEMOLITION PLANS - MONROE ED131 SECOND FLOOR ELECTRICAL DEMOLITION PLANS - MONROE ED132

E - 121ELECTRICAL PLANS - MCMILLAN

BASEMENT ELECTRICAL PLANS - MONROE SECOND FLOOR ELECTRICAL PLANS - MONROE

E - 701ELECTRICAL SCHEDULES





				FITTINGS									
	+	ELBOW		ELBOW - DOUBLE BRANCH	→	REDUCER - CONCENTRIC							
	+	LONG RADIUS ELBOW	+9	ELBOW - SIDE OUTLET UP	—	REDUCER - ECCENTRIC STRAIGHT INVERT							
	→ SR	SHORT RADIUS ELBOW	+9	ELBOW - SIDE OUTLET DOWN		REDUCER - ECCENTRIC STRAIGHT CROWN							
	X	45° ELBOW	— —	ELBOW - OUTLET DOWN]	CAPPED CONNECTION							
	+ .+.	TEE		ELBOW - OUTLET UP		THREADED CONNECTION							
			-121-	TEE - OUTLET DOWN	—	FLANGED CONNECTION							
	-++-	CROSS	-101-	TEE - OUTLET UP		STRAINER							
	*	LATERAL		TEE - SIDE OUTLET DOWN	100	STRAINER WITH BALL VALVE DRAIN							
	†+	TEE - SINGLE SWEEP	+	TEE GIBE GOTEET BOWN	1	STRAINER WITH COUPLER							
	+	TEE SINGLE SWEET	-+0+-	TEE - SIDE OUTLET UP	-D $-$	BUSHING							
			→ >	SIAMESE CONNECTION		FLOW DIRECTION							
	MISCELLANEOUS												
	$\langle \overline{X} \overline{X} \rangle$	EQUIPMENT IDENTIFICATION TAG (ELECTRICAL CONNECTION REQUIRED)	•	NEW CONNECTION POINT WC		WATER CLOSET							
		DETAIL REFERENCE	=	POINT OF DISCONNECT	UR	URINAL							
	-xx	SHEET REFERENCE	OA	OUTSIDE AIR	L S	LAVATORY SINK							
	XX XX	SECTION CUT REFERENCE SHEET REFERENCE	VA EA	VENTILATION AIR EXHAUST AIR	DF	DRINKING FOUNTAIN							
			RA	RELIEF OR RETURN AIR	EWC	ELECTRIC WATER COOLER							
		ELECTRICAL PANEL - SHOWN FOR COORDINATION PURPOSES ONLY	SA	SUPPLY AIR	SS	SERVICE SINK							
		ELECTRICAL PANEL - SHOWN FOR	MA	MIXED AIR	SH DWH	SHOWER							
		COORDINATION PURPOSES ONLY ELECTRICAL PANEL - SHOWN FOR	RF	RELIEF OR RETURN FAN	MSB	DOMESTIC WATER HEATER MOP SINK BASIN							
		COORDINATION PURPOSES ONLY	EF	EXHAUST FAN	MOD	LIGHT LINEWORK = EXISTING OR DEMOLITION							
	T	ELECTRICAL TRANSFORMER - SHOWN FOR COORDINATION PURPOSES ONLY	TYP	TYPICAL		DARK LINEWORK = NEW							
			M	IEDICAL PIPING									
	—ма—	MEDICAL AIR	N	MEDICAL NITROGEN	—	MEDICAL VACUUM							
	NOX	MEDICAL NITROUS OXIDE	ox	MEDICAL OXYGEN	——WAG——	WASTE ANESTHETIC GAS DISPOSAL							
CT)													

GENERAL MECHANICAL NOTES

- A. LIGHT LINE WEIGHT INDICATES EXISTING ITEMS AND ASSOCIATED MATERIALS TO REMAIN. BOLD LINE WEIGHT INDICATES NEW WORK TO BE INSTALLED UNDER THIS CONTRACT.
- B. ROUTING INDICATED ON DRAWINGS IS APPROXIMATE AND DOES NOT INCLUDE ALL OFFSETS, FITTINGS, VALVES, ETC. CONTRACTOR TO FIELD VERIFY DUCT SIZE AND SERVICE PRIOR TO FINAL CONNECTION. COORDINATE LOCATION OF HVAC WORK WITH LIGHTING, STRUCTURAL MEMBERS, PIPING SYSTEMS, ETC. PROVIDE OFFSETS AND CLEARANCES OR RELOCATE HVAC WORK AS REQUIRED TO AVOID CONFLICTS WITH WORK OF ALL OTHER TRADES.
- C. HVAC WORK SHALL NOT BE LOCATED OVER ELECTRICAL, DATA, OR COMMUNICATION EQUIPMENT ROOMS. HVAC WORK SHALL NOT BE LOCATED ABOVE ELECTRICAL / DATA / COMMUNICATION EQUIPMENT OR PANELS.
- D. SUPPORT ALL DUCTWORK, PIPING, EQUIPMENT, ETC. FROM BUILDING STRUCTURE. HOLD PIPING TIGHT TO BOTTOM OF STRUCTURAL MEMBERS OR RUN THROUGH JOIST WEBS IF POSSIBLE. DO NOT USE WIRE OR PERFORATED METAL TO SUPPORT PIPING. DO NOT SUPPORT PIPING FROM OTHER PIPING, DUCTWORK AND/OR ELECTRICAL CONDUITS. DO NOT SUPPORT FROM BOTTOM OF CHORD OF BAR JOIST OR FROM METAL ROOF DECK.
- E. ALL DUCT SIZES SHOWN ARE CLEAR AIRWAY DIMENSIONS. INCREASE SHEET METAL SIZE TO ACCOMMODATE DUCT LINER AS REQUIRED.
- F. ELBOWS SHALL BE CONSTRUCTED WITH CENTERLINE RADIUS OF NOT LESS THAN 1-1/2 TIMES THE WIDTH OF DUCT. WHERE SPACE CONDITIONS DO NOT PERMIT THIS RADIUS OR WHERE INDICATED ON DRAWINGS SQUARE ELBOWS WITH TURNING VANES SHALL BE USED.
- G. SIZE TRANSITIONS WITH A MINIMUM SLOPE OF 1:4.

SPRINKLER - UPRIGHT

SPRINKLER - ZONE CONTROL

- H. PROVIDE DRAW BANDS AND SEAL END OF DUCT INSULATION ON ALL FLEXIBLE CONNECTIONS. MAXIMUM LENGTH OF FLEXIBLE DUCTS SHALL BE THREE FEET.
- I. CONTRACTOR SHALL BE RESPONSIBLE FOR PROPERLY SEALING PENETRATIONS THROUGH A FIRE RATED, SMOKE RATED OR COMBINATION FIRE & SMOKE RATED SEPARATIONS. SEE SPECIFICATIONS FOR FIRE & SMOKE RATED SEALANTS. SEE ARCHITECTURAL PLANS FOR RATED SEPARATIONS.
- J. COORDINATE ALL GRILLE, REGISTER AND DIFFUSER LOCATIONS WITH REFLECTED CEILING PLAN, LIGHT FIXTURES, SPRINKLER HEADS, COMMUNICATION/SOUND DEVICES AND FIRE ALARM DEVICES.
- K. INSTALL ESCUTCHEON PLATES ON ALL WALL PENETRATIONS SERVING ROUND DUCT WALL PENETRATIONS. FABRICATE ESCUTCHEON PLATES TO TRIM THE OPENING IN THE WALL.
- L. INSTALL WALL ANGLE FOR ALL RECTANGULAR DUCT PENETRATIONS THROUGH WALLS.
- M. FOR EXPOSED DUCTWORK THOROUGHLY CLEAN, REMOVE ALL SHIPPING LABELS AND OTHER IDENTIFICATION TAGS. DUCTWORK DESIGNATED TO BE PAINTED SHALL HAVE PHOSPHATIZED FINISH. PROVIDE MILL—PHOSPHATIZED FINISH FOR EXPOSED NOT DESIGNATED TO BE PAINTED. COORDINATE WITH ARCHITECTURAL DRAWINGS DUCTWORK DESIGNATED FOR PAINTING AND EXPOSED DUCTWORK REQUIREMENTS.
- N. PROVIDE DUCT MOUNTED ACCESS DOOR AT FIRE DAMPER, SMOKE DAMPER OR COMBINATION FIRE/SMOKE DAMPERS TO ALLOW FOR MAINTENANCE AND VISUAL INSPECTION PER NFPA REQUIREMENTS.
- O. VOLUME DAMPERS ABOVE INACCESSIBLE CEILINGS SHALL HAVE EXTENSION RODS AND ESCUTCHEON PLATES.
- P. LOCATE AND INSTALL EQUIPMENT TO PROVIDE ALL CODE AND MANUFACTURER'S RECOMMENDED CLEARANCES. KEEP HVAC PIPING, DUCTWORK, ETC. OUT OF CLEARANCE AREAS.
- Q. ALL OPENINGS IN WALLS AND FLOORS FOR PIPING SHALL BE CORE DRILLED OR SAW CUT, UNLESS OTHERWISE NOTED.
- R. ALL HVAC PIPING WORK SHALL BE LOCATED ABOVE CEILINGS, IN A PIPE CHASE, OR OTHER CONCEALED LOCATIONS, UNLESS OTHERWISE NOTED. LOCATE AND ARRANGE VALVES, DRAIN FITTINGS, ETC. TO BE ACCESSIBLE THROUGH LAY—IN CEILINGS, ACCESS PANELS OR ACCESS DOORS. PROVIDE ACCESS PANEL OR ACCESS DOOR FOR ALL VALVES, DRAIN FITTINGS, ETC. AT NON—ACCESSIBLE LOCATIONS.
- S. INSTALL SECTIONAL VALVES ON EACH BRANCH AND/OR RISER SERVING TWO OR MORE HYDRONIC TERMINALS OR EQUIPMENT CONNECTIONS. INSTALL VALVES ADJACENT TO MAIN.
- T. INSTALL SHUTOFF VALVES ON INLET AND OUTLET OF EACH MECHANICAL EQUIPMENT ITEM AND/OR EACH HYDRONIC TERMINAL.
- U. SLOPE HVAC PIPING TO DRAIN VALVES. PROVIDE MANUAL AIR VENTS AT HIGH POINTS AND AT TOP OF RISERS.
- V. SEAL ALL HVAC PENETRATIONS. SEAL PENETRATIONS THROUGH RATED WALLS, FLOORS OR CEILINGS WITH MATERIALS APPROPRIATE FOR RATING.
- W. PIPING IN EXTERIOR WALLS SHALL BE LOCATED ON THE INTERIOR SIDE OF BUILDING INSULATION AND VAPOR BARRIER.
- X. COORDINATE INSTALLATION OF BUILDING INSULATION TO RUN CONTINUOUS BETWEEN PIPING AND EXTERIOR WALL SURFACE.
- Y. PVC PIPING SHALL NOT BE INSTALLED IN ANY RETURN AIR PLENUM UNLESS THE PIPING IS INSTALLED IN A PRE-APPROVED RATED ASSEMBLY.
- Z. COORDINATE DUCTWORK WITH STRUCTURAL CROSS BRACING. PROVIDE TOP AND BOTTOM BRIDGING BETWEEN JOISTS WHERE DUCTWORK IS TO BE INSTALLED BETWEEN THE JOISTS. COORDINATE WITH ALL TRADES.

GENERAL MECHANICAL DEMOLITION NOTES

- A. CROSSHATCHING INDICATES EXISTING ITEMS AND ASSOCIATED MATERIALS SHALL BE REMOVED.
- B. DRAWINGS INDICATE APPROXIMATE ROUTING OF PIPING, DUCTWORK AND MAJOR COMPONENTS AND DO NOT INCLUDE ALL OFFSETS, FITTINGS, VALVES, ETC. CONTRACTOR SHALL FIELD VERIFY EXACT SIZE AND ROUTING PRIOR TO REMOVAL OR RELOCATION. CONTRACTOR SHALL ALSO BE RESPONSIBLE FOR REMOVAL OF MISCELLANEOUS MECHANICAL ITEMS LOCATED ON OR IN ANY WALLS TO BE REMOVED.
- C. EXISTING INSULATION DAMAGED DURING DEMOLITION / CONSTRUCTION ACTIVITIES SHALL BE REPAIRED WITH SIMILAR MATERIALS.
- D. ALL OPENINGS THROUGH WALLS AND FLOOR SLABS NOT BEING REUSED SHALL BE PATCHED WITH LIKE MATERIALS AND PAINTED TO MATCH EXISTING.
- E. ALL OPENINGS THROUGH ROOF NOT BEING REUSED SHALL BE PATCHED WITH LIKE MATERIALS AND SEALED WATERTIGHT.

GENERAL PLUMBING NOTES

- A. LIGHT LINE WEIGHT INDICATES EXISTING ITEMS AND ASSOCIATED MATERIALS TO REMAIN. BOLD LINE WEIGHT INDICATES NEW WORK TO BE INSTALLED UNDER THIS CONTRACT.
- B. ROUTING INDICATED ON DRAWINGS IS APPROXIMATE AND DOES NOT INCLUDE ALL OFFSETS, FITTINGS, VALVES, ETC. CONTRACTOR TO FIELD VERIFY PIPE SIZE AND SERVICE PRIOR TO FINAL CONNECTION. COORDINATE LOCATION OF PLUMBING PIPING WORK WITH LIGHTING, STRUCTURAL MEMBERS, HVAC, PIPING SYSTEMS, ETC. PROVIDE OFFSETS AND CLEARANCES OR RELOCATE PLUMBING WORK AS REQUIRED TO AVOID CONFLICTS WITH WORK OF ALL OTHER TRADES.
- C. PLUMBING WORK SHALL NOT BE LOCATED OVER ELECTRICAL, DATA OR COMMUNICATION EQUIPMENT ROOMS. PLUMBING WORK SHALL NOT BE LOCATED ABOVE ELECTRICAL / DATA / COMMUNICATION EQUIPMENT OR PANELS.
- D. SUPPORT ALL PLUMBING PIPING, EQUIPMENT, ETC. FROM BUILDING STRUCTURE. HOLD PIPING TIGHT TO BOTTOM OF STRUCTURAL MEMBERS OR RUN THROUGH JOIST WEBS IF POSSIBLE. DO NOT USE WIRE OR PERFORATED METAL TO SUPPORT PIPING. DO NOT SUPPORT PIPING FROM OTHER PIPING, DUCTWORK AND/OR ELECTRICAL CONDUITS. DO NOT SUPPORT FROM BOTTOM OF CHORD OF BAR JOIST OR FROM METAL ROOF DECK.
- E. ROUTE ABOVE GRADE DRAINAGE PIPING AS HIGH AS POSSIBLE AND COORDINATE WITH OTHER TRADES.
- F. CONTRACTOR SHALL BE RESPONSIBLE FOR PROPERLY SEALING PENETRATIONS THROUGH A FIRE RATED, SMOKE RATED OR COMBINATION FIRE & SMOKE RATED SEPARATIONS. SEE SPECIFICATIONS FOR FIRE & SMOKE RATED SEALANTS. SEE ARCHITECTURAL PLANS FOR RATED SEPARATIONS.
- G. INSTALL ESCUTCHEON PLATES ON ALL WALL AND FLOOR PENETRATIONS SERVING EXPOSED PLUMBING PIPING WALL PENETRATIONS.
- H. ALL OPENINGS IN WALLS AND FLOORS FOR PIPING SHALL BE CORE DRILLED OR SAW CUT, UNLESS OTHERWISE NOTED.
- I. LOCATE AND INSTALL EQUIPMENT TO PROVIDE ALL CODE AND MANUFACTURER'S RECOMMENDED CLEARANCES. KEEP HVAC PIPING, DUCTWORK, ETC. OUT OF CLEARANCE AREAS.
- J. ALL PLUMBING PIPING WORK SHALL BE LOCATED ABOVE CEILINGS, IN A PIPE CHASE, OR OTHER CONCEALED LOCATIONS, UNLESS OTHERWISE NOTED. LOCATE AND ARRANGE VALVES, DRAIN FITTINGS, ETC. TO BE ACCESSIBLE THROUGH LAY—IN CEILINGS, ACCESS PANELS OR ACCESS DOORS. PROVIDE ACCESS PANEL OR ACCESS DOOR FOR ALL VALVES, DRAIN FITTINGS, ETC. AT NON—ACCESSIBLE LOCATIONS.
- K. INSTALL SECTIONAL VALVES ON EACH BRANCH AND/OR RISER SERVING TWO OR MORE PLUMBING FIXTURES OR EQUIPMENT CONNECTIONS. INSTALL VALVES ADJACENT TO MAIN.
- L. INSTALL SHUTOFF VALVES ON INLET AND OUTLET OF PLUMBING EQUIPMENT.
- M. INSTALL STOPS AT EACH PLUMBING FIXTURE EXCEPT AT FLUSHOMETER LOCATIONS.
- N. SEAL ALL PLUMBING PIPING PENETRATIONS. SEAL PENETRATIONS THROUGH RATED WALLS, FLOORS OR CEILINGS WITH MATERIALS APPROPRIATE FOR RATING.
- O. PIPING IN EXTERIOR WALLS SHALL BE LOCATED ON THE INTERIOR SIDE OF BUILDING INSULATION AND VAPOR BARRIER.
- P. COORDINATE INSTALLATION OF BUILDING INSULATION TO RUN CONTINUOUS BETWEEN PIPING AND EXTERIOR WALL SURFACE
- Q. COORDINATE EXACT LOCATION OF FLOOR DRAINS AND FLOOR SINKS. TOP OF GRATE SHALL BE 1/8" BELOW FINISHED FLOOR ELEVATION.
- R. COMPLY WITH LOCAL UTILITY COMPANY RULES AND REGULATIONS FOR ALL GAS METER INSTALLAIONS. COORDINATE EXACT LOCATION OF GAS CONNECTIONS WITH EQUIPMENT SUPPLIED.
- S. COPPER PIPING LOCATED ABOVE GRADE SHALL BE TYPE "L"; COPPER PIPING LOCATED BELOW GRADE SHALL BE TYPE "K" AND RUN CONTINUOUS WITHOUT JOINTS BELOW GRADE. TYPE "M" COPPER SHALL NOT BE USED ON PRESSURIZED PIPING SYSTEMS.
- T. DRAINAGE PIPING 3 INCHES AND SMALLER SHALL SLOPE NO LESS THAN 1/4 INCH PER FOOT. DRAINAGE PIPING 4 INCHES AND LARGER SHALL SLOPE NO LESS THAN 1/8 INCH PER FOOT.
- PIPING 4 INCHES AND LARGER SHALL SLOPE NO LESS THAN 1/8 INCH PER FOOT.


 U. INSTALL WALL CLEAN OUTS (WCO) WHEN LOCATED BEHIND A WATER CLOSET AT 30" A.F.F. OR AT 42"
- A.F.F. ABOVE CABINETRY ON ALL SANITARY & STORM STACKS.


 V. COORDINATE EXACT STORM PIPE CONNECTIONS WITH STORM DRAIN LOCATIONS SHOWN ON ARCHITECTURAL
- ROOF PLAN.
- W. INSTALL VENT-THRU-ROOF (VTR) A MINIMUM OF 10'-0" AWAY FROM ANY OUTSIDE AIR INTAKE.
- X. REMOVE, REPAIR AND REPLACE WALLS, FLOORS, ROOFS AND CEILINGS TO MATCH EXISTING, WHERE NECESSARY FOR PIPING AND FIXTURE REMOVAL & INSTALLATION.
- Y. KITCHEN EQUIPMENT FURNISHED BY KITCHEN EQUIPMENT CONTRACTOR PLUMBING CONTRACTOR SHALL ROUGH—IN AND MAKE FINAL CONNECTIONS TO UTILITIES REQUIRED AND PROVIDE PIPING, STOPS, WATER HAMMER ARRESTERS, TRAPS AND FITTINGS FOR EQUIPMENT TO BE IN OPERATIONAL ORDER. COORDINATE WITH KITCHEN EQUIPMENT SUPPLIER FOR CONNECTIONS AND LOCATIONS. SEE KITCHEN EQUIPMENT CONNECTION SCHEDULE FOR RESPONSIBILITY OF WHO FURNISHES VACUUM BREAKERS AND PRESSURE REDUCING VALVES.
- Z. PVC PIPING SHALL NOT BE INSTALLED IN ANY RETURN AIR PLENUM UNLESS THE PIPING IS INSTALLED IN A PRE-APPROVED RATED ASSEMBLY.
- AA. PROVIDE ACCESSIBLE SHUTOFF VALVE INSIDE THE BUILDING FOR EACH WALL HYDRANT.
- AB. CONTRACTOR SHALL COORDINATE ALL CONNECTIONS OF PLUMBING SYSTEMS WITH EXTERIOR SITE UTILITIES AND SERVICES PRIOR TO INSTALLING ANY PIPING ON THE INTERIOR. CONTRACTOR SHALL CONFIRM THAT ALL INTERIOR PIPE INVERTS AND PIPE INVERTS AT THE 5' LINE MATCH EXTERIOR PIPE INVERTS, PRIOR TO INSTALLING ANY INTERIOR PIPING BELOW FLOOR.

DO NOT SCALE DRAWINGS. VERIFY ALL DIMENSIONS AND CLEARANCES FROM ARCHITECTURAL, STRUCTURAL, SHOP AND OTHER APPROPRIATE DRAWINGS OR AT SITE. LAY OUT AND COORDINATE ALL WORK PRIOR TO INSTALLATION TO PROVIDE CLEARANCES REQUIRED FOR OPERATION, MAINTENANCE, AND CODES. VERIFY NON—INTERFERENCE WITH OTHER WORK. DO NOT FABRICATE PRIOR TO VERIFICATION OF CLEARANCES FOR ALL TRADES. THIS NOTICE APPLIES TO ALL FARRIS ENGINEERING PLANS.

FARRIS ENGINEERING







OPS Pool HVAC Upgrade

— <u>DESIGNED BY:</u> -**RER**— <u>DRAWN BY:</u> — **MAN**

CHECKED BY:

12/29/2023
- PROJECT NO:
232051


MECHANICAL
SYMBOLS LEGEND
AND GENERAL
NOTES


M-001


POST INDICATOR VALVE


—₩—


CIRCUIT SETTER































DESIGNED BY: -DRAWN BY: — - CHECKED BY: PROJECT NO: -







G: \2023\232051\CAD\HVAC\232051_M-131-Monroe.dwg M-131 12/22/23 4:45pm lmb

E FARRIS ENGINEERING


FARRIS

OMAHA | LINCOLN | SIDN

farris-u



COPYRIGHT: This document and the information contained may not be reproduced or excerpted from without express written permission of FARRIS ENGINEERING, INC. Unauthorized copying, disclosure or construction use are prohibited by the copyright law.



OPS Pool HVAC Upgrade

DESIGNED BY: —
RER

DRAWN BY: —
MAN

CHECKED BY: —
RER


DATE: —
12/29/2023

PROJECT NO: —

- SHEET TITLE
BASEMENT
MECHANICAL
PLANS MONROE

232051

M-131



POOL AIR CONDITIONING UNIT SCHEDULE

L																										
ſ				MIN.		SUPPLY FAN		EVAPO	RATOR	COIL			AUX HEAT				DX COIL		нот о	GAS REHEAT	POOL V	WATER H	EATING C	OIL		
	MARK	LOCATION	CFM	O.A. CFM	SUPPLY EXT. S.P.	(QTY) CFM EACH	CFM	MEDIUM	SEN	тот	FLOW RATE	MEDIUM	EAT (DB) LAT (DB)	CAPACITY (MBH)	CFM	SENSIBLE (MBH)	TOTAL (MBH)	CIRCUITS	CFM	SENSIBLE (MBH)	MAT	МВН	ΔP (PSI)	FLOW RATE	MANUFACTURER & MODEL NO.	REMARKS
Ī	DH-1	MCMILLIAN	9,000	3,000	1.50"	(1) 9000	9000	R410A	158.0	287.0		STEAM	82 / 105	447	9000	313	569	2	9000	711.5	TITANIUM	390.0	10.0	70.0	POOL PAK PCP-3535-PG-I	1 - 7, 9
	DH-2	MCMILLIAN	9,000	3,000	1.50"	(1) 9000	9000	R410A	158.0	287.0		STEAM	82 / 105	447	9000	313	569	2	9000	711.5	TITANIUM	390.0	10.0	70.0	POOL PAK PCP-3535-PG-I	1 - 7, 9
	DH-3	MONROE	11,000	3,000	1.50"	(1) 11000						HOT WATER	82 / 124	360	11000	155	281	2	11000	351	TITANIUM	204	10	36	POOL PAK PCP-3535-NG-I	1-6, 8, 9

- SEE MECHANICAL/ELECTRICAL COORDINATION SCHEDULE FOR ELECTRICAL DATA.
- PROVIDE WITH MODULATING COMPRESSORS FOR DX COOLING, MINIMUM OF 2 CIRCUITS
- UNIT SHALL BE RATED FOR INDOOR APPLPICATION, 2" THICK DOUBLE WALL THERMAL BREAK PANELS, FOAM INJECTED PANELS AT 2LB/CUBIC FOOT, ALUMINUM INNER WALL
- PROVIDE WITH FULLY PROGRAMMED DDC CONTROLLER WITH BMS INTERFACE TO WORK WITH TRANE TRACER SYSTEM
- PROVIDE UNIT WITH SIDE SUPPLY AND RETURN OPENINGS WITH DUCT CONNECTIONS
- PROVIDE WITH ALL ALUMINUM SENSIBLE PLATE CROSS FLOW HEAT EXCHANGER
- UNIT IS COMPRISED OF TWO UNIT TWINNED TOGETHER. UNIT SHALL OPERATE AS A SINGLE UNIT.
- PROVIDE EXHASUT FAN SEPARTATELY. PROVIDE UNIT WITH INTEGRAL DISCONNECT.

			<u>\$</u>	L FILTE	R SCI	HEDULE)		
MARK	LOCATION	GPM	1 510 111 5122 112121		VOL GAL	MANUFACTURER MODEL	SI DIA	HEIGHT	REMARKS
PF-1	BRYAN	375	3	381	159	NEPTUNE SP-27-48-487	34	98"	1
PF-2	BURKE	450	3	381	159	NEPTUNE SP-27-48-487	34	98"	1
PF-3	MCMILLAN	540	3	572	250	NEPTUNE SP-33-48-732	40	104"	1
PF-4	MONROE	450	3	381	159	NEPTUNE SP-27-48-487	34	98"	1

١R	KS:
	CONTRACTOR TO VERIFY FLOW RATES OF EXISTING FILTRATION SYSTEMS.

AIR COOLED CONDENSING UNIT SCHEDULE COMPRESSORS CONDENSER FANS MARK SERVES REMARKS EVAP. MBH TEMP. NO. RLA(EA) LRA(EA) KW(EA) NO. HP(EA) FLA(EA) 21.20 NC-Z-4V-2C POOL PAK ACC-2 DH-2 358.9 100° F 21.20 122 NC-Z-4V-2C

SEE MECHANICAL/ELECTRICAL COORDINATION SCHEDULE FOR ELECTRICAL DATA.

MECHANICAL / ELECTRICAL COORDINATION SCHEDULE

ABBREVIA ⁻

				ΓΙΟΝ:			
Е	ELECTRICAL CONTRACTOR	HP	HORSEPOWER	4X	NEMA 4X	V	VOLTAGE
М	MECHANICAL CONTRACTOR	KW	KILOWATTS	PH	PHASE	VFD	VARIABLE F
- 1	INTEGRAL WITH EQUIPMENT	MR	PER MANUFACTURER'S	RE	REVERSING		DRIVE
С	COMBINATION STARTER AND		RECOMMENDATION	RV	REDUCED VOLTAGE	2S	TWO SPEED
	SAFETY SWITCH	NF	NON-FUSED	SF	FUSE HOLDER WITH SWITCH	3S	THREE SPE
CB	CIRCUIT BREAKER	NR	NON-BEVERSING	22	SAFETY SWITCH		

CB CIRCUIT BREAKER FV FULL VOLTAGE FLA FULL LOAD AMPS

	REFER TO SPECIFICATIONS	S FOR A	DDITIONAL REQUIREMENTS
3R	NEMA 3R	ST	THERMAL ELEM. SWITCH
N1	NEMA 1	SH	HP RATED SWITCH
INIT	NON-REVERSING	33	SAFEIT SWITCH

<u>ABBREVIAT</u>	TON:		
4X	NEMA 4X	V	VOLTAGE
PH	PHASE	VFD	VARIABLE FREQUENC
RE	REVERSING		DRIVE
RV	REDUCED VOLTAGE	2S	TWO SPEED
SF	FUSE HOLDER WITH SWITCH	3S	THREE SPEED
SS	SAFETY SWITCH		
SH	HP RATED SWITCH		


	REFER TO SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS													
			RATING			DIS	CONNECT			мото	R STARTE	R	NAMEPLATE	
MARK	DESCRIPTION		KATING	1	FURNISH/		RATING	FUSE		FURNISH/	TYPE/		MINIMUM	REMARKS
		LOAD	V	PH	INSTALL BY	TYPE	(AMPS)	SIZE	ENCL.	INSTALL BY	NEMA SIZE	ENCL.	SCCR (AMPS)	
	DH-1 MCMILLAN	130 FLA	460	3	M/M	-	-	-	-	M/M	-	-		
	UV-1 MCMILLAN	2 @ 522 W	120	1	E/E	SH	20	-	3R	-	-	-	-	
	F-1 MCMILLAN	0.14 BHP	120	1	E/E	SH	20	-	3R	-	-	-	-	
	DH-2 MONROE	70.2 FLA	460	3	M/M	ı	-	1	-	M/M	-	-		
	UV-2 MONROE	2 @ 435 W	120	1	E/E	SH	20	1	3R	-	-	-	-	
	F-2 MONROE	0.14 BHP	120	1	E/E	SH	20	-	3R	-	-	-	-	

GENERAL NOTES:

- VERIFY/COORDINATE ALL RATINGS FOR EQUIPMENT. WHERE SUCH RATINGS ARE OTHER THAN THAT INDICATED ON MECHANICAL/ELECTRICAL COORDINATION SCHEDULE, PROVIDE DISCONNECTS, MOTOR STARTERS, OVERCURRENT DEVICES AND RELATED REVISIONS ACCORDINGLY. WHERE EQUIPMENT IS PROVIDED WITH RATINGS OTHER THAN THAT INDICATED, CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATION AND ASSOCIATED COSTS FOR REVISIONS.
- PROVIDE FRACTIONAL HORSEPOWER MOTORS WITH INTEGRAL OVERLOAD PROTECTION.
- EQUIPMENT LISTED IN SCHEDULE MAY APPEAR IN NUMEROUS LOCATIONS. EQUIPMENT MARKS ARE DESIGNATED BY UNIQUE IDENTIFIERS ON THE PLANS; I.E., HP-1.1 HP-1.2. IN THESE INSTANCES, THE ELECTRICAL REQUIREMENTS DO NOT CHANGE FROM ONE MARK TO THE NEXT, ONLY THE UNIQUE IDENTIFIER CHANGES.
- HORSEPOWER RATED SWITCHES (SH): FOR 120 V MOTORS LESS THAN 1/2 HP, PROVIDE FUSEHOLDER WITH SWITCH, FUSED PER MANUFACTURER'S RECOMMENDATION AND NEC REQUIREMENTS. FOR 120 V MOTORS RATED 1/2 HP OR 3/4 HP, PROVIDE HP RATED TOGGLE SWITCH (WHERE BRANCH CIRCUIT OVERCURRENT DEVICE MEETS NEC REQUIREMENTS FOR SHORT-CIRCUIT PROTECTION) OR FUSED SAFETY SWITCH.
- INDUSTRIAL CONTROL PANELS AS DEFINED BY NEC ARTICLE 409, MOTOR CONTROLLERS, HERMETIC REFRIGERANT MOTOR COMPRESSORS AND EQUIPMENT SHALL BE MARKED WITH INFORMATION AS REQUIRED BY THE NATIONAL ELECTRICAL CODE (NEC). MARK IN ACCORDANCE WITH NEC ARTICLE 409.110 FOR INDUSTRIAL CONTROL PANELS, NEC ARTICLE 430.8 FOR CONTROLLERS AND NEC ARTICLE 440.4(B) FOR HERMETIC REFRIGERANT MOTOR COMPRESSORS AND EQUIPMENT. THE MARKED SHORT CIRCUIT CURRENT RATING (SCCR) SHALL BE NO LESS THAN THE VALUE INDICATED ABOVE.
- FOR MOTORS CONTROLLED BY VARIABLE FREQUENCY DRIVES, PROVIDE FACTORY INSTALLED SHAFT GROUNDING THAT REQUIRES NO MAINTENANCE FOR THE SERVICE LIFE OF THE MOTOR.

- PROVIDE EXHAUST FAN MOTOR FACTORY-WIRED TO WEATHERPROOF JUNCTION BOX INTEGRAL WITH FAN. ELECTRICAL CONTRACTOR TO PROVIDE WEATHERPROOF HORSEPOWER RATED SWITCH (SEE GENERAL NOTES ABOVE).
- PROVIDE LOCKABLE DISCONNECT INTEGRAL WITH VFD.
- ELECTRICAL CONTRACTOR TO PROVIDE DISCONNECT AND STARTER INTEGRAL WITH MOTOR CONTROL CENTER.

ARK	LOCATION	GPM	LINE SIZE IN	UV LAMPS	MANUFACTURER MODEL	REMARKS
F-3	MCMILLAN	540	6	1 @ 3KW	DELTA EM SERIES 600 EL	1
PF-4	MONROE	450	6	1 @ 3KW	DELTA EM SERIES 600 EL	1




	FAN SCHEDULE													
MARK	SERVES	SCHOOL	TYPE	AIRFLOW	ESP	FAN SPEED	DRIVE TYPE	ELEC	CTRICAL	DATA	MAX SOUND	SPEED	MANUFACTURER &	REMARKS
WARK	SERVES	SCHOOL	ITPE	(CFM)	(IN WG)	(RPM)	DRIVE TIPE	V	PH	HP	(dBA)	CONTROL	MODEL NO.	KEWIAKKS
F-1	CHEMICAL STORAGE ROOMS	MONROE	INLINE	100	1.00	1750	ECM	120	1	0.5	62	NOTE 2	GREENHECK SQ-97-VG	1, 2, 3
RF-1	RELIEF	MONROE	INLINE	3000	0.25	1200	ECM	460	3	1	66	YES	GREENHECK SQ-160-VG	1, 3
F-2	CHEMICAL STORAGE ROOMS	MCMILLIAN	INLINE	100	1.00	1750	ECM	120	1	0.5	62	NOTE 2	GREENHECK SQ-97-VG	1, 2, 3
DEMVDK6.														

FAN TO HAVE PAINTED STEEL COMPONENTS.

SEE MECHANICAL/ELECTRICAL COORDINATION SCHEDULE FOR ELECTRICAL DATA. FAN TO HAVE SPEED ADJUSTMENT ON FAN FOR BALANCING PURPOSES.

ENGINEERING





DESIGNED BY: -DRAWN BY: — CHECKED BY: – DATE: — 12/29/2023 PROJECT NO:

> $oldsymbol{---}$ SHEET TITLE $oldsymbol{--}$ MECHANICAL SCHEDULES

232051

GENERAL ELECTRICAL DEMOLITION NOTES

- A. COMPLETELY REMOVE ALL ELECTRICAL WIRING, CONDUIT, SWITCHES, DISCONNECTS, LUMINAIRES, AND ASSOCIATED ANCILLARY EQUIPMENT SHOWN CROSSHATCHED. ITEMS INDICATED FOR REMOVAL ARE ONLY SUGGESTIVE OF THE AMOUNT OF DEMOLITION WORK INVOLVED. PERFORM A SITE INVESTIGATION TO AID IN DETERMINING THE COMPLETE EXTENT OF DEMOLITION WORK.
 - B. COORDINATE AND SCHEDULE ALL NECESSARY POWER OUTAGES WITH THE OWNER'S REPRESENTATIVE PRIOR TO PROCEEDING WITH SUCH WORK SO OPERATIONS IN ADJACENT OCCUPIED PORTIONS OF THE BUILDING ARE NOT INTERRUPTED OR RESTRICTED WITHOUT PRIOR APPROVAL.
 - C. REMOVE ALL EXISTING BRANCH CIRCUITS INDICATED AS COMPLETELY AS POSSIBLE. REMOVE EXISTING CONDUCTORS COMPLETELY FROM THEIR RACEWAYS AND DO NOT REUSE EXCEPT WHERE SPECIFICALLY INDICATED. WHERE AN EXISTING DEVICE IS REMOVED FROM AN EXISTING CIRCUIT, PROVIDE NEW WIRING AND MAINTAIN CONTINUITY OF EXISTING CIRCUIT.
 - D. REMOVE EXISTING LUMINAIRES, LAMPS, BALLASTS, AND RELATED COMPONENTS INDICATED AS COMPLETELY AS POSSIBLE. DELIVER EQUIPMENT CONSIDERED SALVAGEABLE BY THE OWNER'S REPRESENTATIVE AND NOT SHOWN FOR REUSE TO THE OWNER'S STORAGE LOCATION. REMOVE NON—SALVAGEABLE EQUIPMENT FROM THE SITE. PROPERLY DISPOSE OF LAMPS AND BALLASTS CONSIDERED HAZARDOUS WASTE.
- E. REMOVE EXISTING SURFACE MOUNTED BOXES, CONDUIT, SURFACE METAL RACEWAY, WIREWAY, ETC. INDICATED AS COMPLETELY AS POSSIBLE. PATCH ABANDONED PENETRATIONS FROM REMOVED FASTENERS. ABANDON IN PLACE NON—ACCESSIBLE BOXES SHOWN REMOVED AND COVER WITH STAINLESS STEEL COVER PLATES. ABANDON IN PLACE NON—ACCESSIBLE CONDUIT SHOWN REMOVED AND CAP OFF IN A SUITABLE MANNER PER LOCAL INSPECTOR'S REQUIREMENTS. CHISEL RACEWAYS STUBBED FROM A CONCRETE FLOOR OR WALL 2 INCHES BELOW ADJACENT SURFACE, GROUT, AND SCREED.
- F. COORDINATE REUSED EXISTING BOX AND CONDUIT LOCATIONS WITH NEW WORK LOCATIONS.
- G. REMOVE ELECTRICAL WORK AT ALL MECHANICAL EQUIPMENT SHOWN REMOVED. COORDINATE EQUIPMENT REMOVAL LOCATIONS WITH MECHANICAL DRAWINGS.
- H. OPS HAS FIRST RIGHTS TO SALVAGE ANY ITEMS TO BE REMOVED FROM SITE. CONTRACTOR IS RESPONSIBLE FOR DISPOSING OF BALANCE OF DEMOLITION MATERIALS, INCLUDING LIGHTING BALLASTS.

GENERAL ELECTRICAL NOTES APPLY TO ALL ELECTRICAL SHEETS


A. MOUNTING HEIGHTS INDICATED ARE TO CENTER OF RO

- A. MOUNTING HEIGHTS INDICATED ARE TO CENTER OF ROUGH—IN ABOVE FINISHED FLOOR (AFF).
- B. INSTALL ALL CONDUCTORS IN CONTINUOUS RACEWAY. PROVIDE INSULATED EQUIPMENT GROUNDING CONDUCTOR.
- C. PROVIDE DEDICATED NEUTRAL CONDUCTOR FOR EACH BRANCH CIRCUIT PHASE CONDUCTOR. EXCEPTION: WHERE AN EQUIPMENT MANUFACTURER REQUIRES A MULTIWIRE BRANCH CIRCUIT FOR ONLY ONE UTILIZATION EQUIPMENT AND WHERE ALL UNGROUNDED CONDUCTORS OF THAT CIRCUIT ARE OPENED SIMULTANEOUSLY BY THE BRANCH CIRCUIT OVERCURRENT DEVICE.
- D. CONCEAL ALL CONDUITS IN NEW WALLS, EXISTING STUD WALLS, OR ABOVE SUSPENDED CEILINGS.
- E. WHERE CONDUIT CANNOT BE CONCEALED IN EXISTING WALL OR CEILING CAVITIES, INSTALL CONDUCTORS IN SURFACE METAL RACEWAYS; SURFACE CONDUIT OR METAL SURFACE RACEWAY AT ENGINEER'S DISCRETION.
- F. PAINT SURFACE CONDUIT IN FINISHED AREAS, WHEN ALLOWED, TO MATCH SURROUNDING SURFACES. COORDINATE FINISHES WITH ARCHITECT.
- G. METAL SURFACE RACEWAYS SHALL BE WIREMOLD #V500, #V700, OR #V2400 SERIES WITH FACTORY IVORY FINISH OR APPROVED EQUIVALENT. METAL SURFACE RACEWAYS FOR TELEVISION CABLE SHALL BE WIREMOLD #V700 OR LARGER. METAL SURFACE RACEWAYS FOR TELECOMMUNICATIONS CABLES SHALL BE #V2400 OR LARGER. COMPLY WITH EIA/TIA STANDARDS FOR CABLE BENDING RADIUS.
- INSTALL EXPOSED OR CONCEALED RACEWAY NEAR METAL CORRUGATED SHEET ROOF DECKING SO NEAREST OUTER RACEWAY SURFACE IS NOT LESS THAN 6 INCHES FROM THE NEAREST SURFACE OF THE ROOF DECKING. EXCEPTION: RIGID METAL CONDUIT AND INTERMEDIATE METAL CONDUIT SHALL NOT BE REQUIRED TO MAINTAIN THIS CLEARANCE.
- I. PATCH, PAINT, REPAIR OR REPLACE ALL WALLS, CEILINGS, OR OTHER BUILDING ELEMENTS DISTURBED DURING INSTALLATION OF ELECTRICAL WORK
- J. USE ROOM NUMBERS ASSIGNED BY OPS AND NOT ROOM NUMBERS LISTED ON DRAWINGS FOR LABELING OF PANELBOARD DIRECTORIES, FIRE ALARM PANEL PROGRAMMING, ETC. INCLUDE A DESCRIPTION OF LOAD SUCH AS LIGHTS, RECEPTACLES, MECHANICAL UNIT LOCATIONS, ETC. ON TYPED PANELBOARD DIRECTORIES.
- K. REFER TO MECHANICAL/ELECTRICAL COORDINATION SCHEDULE SHEET M-701 FOR ADDITIONAL REQUIREMENTS ON DISCONNECTS, MOTOR STARTERS, ETC.
- L. CONNECT SMOKE AND FIRE/SMOKE DAMPERS TO 120V POWER AND CONTROL WITH FIRE ALARM SYSTEM. VERIFY EXACT QUANTITY AND LOCATION OF DAMPERS WITH MECHANICAL DRAWINGS.
- I. COORDINATE LOCATION OF RECESSED LUMINAIRES, SPEAKERS, ETC. WITH FIRE RATED CEILINGS. PROVIDE ENCLOSURES TO MAINTAIN THE FIRE INTEGRITY RATING OF THE CEILING. COORDINATE EXACT LOCATIONS OF FIRE RATED CEILINGS WITH ARCHITECTURAL DRAWINGS.

FARRIS ENGINEERIN



COPYRIGHT: This document and the information contained may not be reproduced or excerpted from without express written permission of FARRIS ENGINEERING, INC. Unauthorized copying, disclosure or construction use are prohibited by the copyright law.



OPS Pool AC Upgrade

— DESIGNED BY: —
BEL
— DRAWN BY: —
BEL
— CHECKED BY: —
EMN

____ <u>DATE:</u> ____ 12/29/2023

PROJECT NO: -232051

SHEET TITLE

ELECTRICAL
SYMBOLS LEGEND
AND GENERAL
NOTES

E-001

NOTICE:
DO NOT SCALE DRAWINGS. VERIFY ALL DIMENSIONS AND
CLEARANCES FROM ARCHITECTURAL, STRUCTURAL, SHOP
AND OTHER APPROPRIATE DRAWINGS OR AT SITE. LAY OUT
AND COORDINATE ALL WORK PRIOR TO INSTALLATION TO
PROVIDE CLEARANCES REQUIRED FOR OPERATION,
MAINTENANCE, AND CODES. VERIFY NON-INTERFERENCE
WITH OTHER WORK. DO NOT FABRICATE PRIOR TO
VERIFICATION OF CLEARANCES FOR ALL TRADES. THIS
NOTICE APPLIES TO ALL FARRIS ENGINEERING PLANS.

/ NL <

__s__

EMERGENCY CIRCUIT

NIGHT LIGHTING CIRCUIT


SOUND SYSTEM RACEWAY


CONDUIT SEAL

CONDUIT SLEEVE (NUMBER INDICATES SIZE)

-··- CABLE TRAY


[] #"





G:\2023\232051\CAD\Electrical\232051_ED131-Monroe.dwg ED131 12/22/23 2:51pm blassek








DESIGNED BY: -BEL DRAWN BY: — BEL - CHECKED BY: — <u>DATE:</u> — 12/29/2023 — PROJECT NO: — 232051

> — SHEET TITLE — **BASEMENT ELECTRICAL DEMOLITION** PLANS -**MONROE**

— <u>SHEET NO</u> — **ED131**









1 CONNECT TO NEAREST NON-SWITCHED EXISTING LIGHTING CIRCUIT.

FARRIS ENGINEERING






OPS Pool HVAC Upgrade


DESIGNED BY: -BEL DRAWN BY: — BEL CHECKED BY: **EMN** — <u>DATE:</u> — 12/29/2023 PROJECT NO: -232051

SHEET TITLE -**BASEMENT ELECTRICAL** PLANS -**MONROE**




FARRIS ENGINEERING

OMAHA | LINCOLN | SIDNEY | COLORADO SPRINGS farris-usa.com



COPYRIGHT: This document and the information contained may not be reproduced or excerpted from without express written permission of FARRIS ENGINEERING, INC. Unauthorized copying, disclosure or construction use are prohibited by the copyright law.



OPS Pool HVAC Upgrade

SHEET TITLE

SECOND FLOOR

ELECTRICAL

PLANS
MONROE

F-132


			LUMINAIRE SCHED	ULE							
MARK	DESCRIPTION	DESCRIPTION MANUFACTURER/SERIES CATALOG NO.		QTY	LIGHT SOURCE TYPE	FINISH	MOUNTING	INPUT WATTS	VOLTS	ACCEPTABLE MANUFACTURERS	REMARKS
А	GASKETED, ENCLOSED CORROSION-RESISTANT INDUSTIAL	LITHONIA	DMW2 L24-3000LM-AFL-MD-MVOLT-GZ10-40K- 80CRI-WLFEND2-STSL	-	3000LM/4000K/LED	WHITE	SUSPENDED	27	120/277	REMARK1	2

LUMINAIRE SCHEDULE REQUIREMENTS:


- A. SUBMIT SHOP DRAWINGS FOR EACH LUMINAIRE, BALLAST/DRIVER, AND LAMP TYPE USED ON PROJECT.
- B. ACCEPTABLE MANUFACTURERS LISTED ARE CAPABLE OF PROVIDING EQUIVALENT LUMINAIRES. SUBMIT PRODUCT AND ACCESSORIES EQUIVALENT OR SUPERIOR TO THE SPECIFIED LUMINAIRE IN PHOTOMETRIC PERFORMANCE, CONSTRUCTION QUALITY, INCLUDED ACCESSORIES, AND AESTHETICS. ADDITIONAL MANUFACTURERS NOT LISTED MAY ALSO BE SUBMITTED FOR APPROVAL PRIOR TO BID. APPROVAL WILL BE BASED ON AN ASSESSMENT OF THE PRODUCT'S QUALITY, PHOTOMETRIC PERFORMANCE, INCLUDED ACCESSORIES, AND AESTHETICS.
- C. ALL LUMINAIRES SHALL HAVE A U.L. LABEL. ALL LUMINAIRES USED IN EXTERIOR APPLICATIONS SHALL HAVE A U.L. WET LABEL.
- D. VERIFY MOUNTING COMPATIBILITY OF LUMINAIRES WITH CEILING SYSTEMS/MATERIALS PRIOR TO ORDERING LUMINAIRES. NOTIFY ENGINEER OF ANY CONFLICTS WITH THE PROPOSED INSTALLATION.
- E. PROVIDE FACTORY INSTALLED INTEGRAL DISCONNECTING MEANS FOR LUMINAIRES PER 2014 NEC ARTICLE 410.130.(G). NOTE THAT EXCEPTION NO. 4 WILL NOT BE ACCEPTED.
- F.. PHILIPS, OSRAM SYLVANIA, G.E., CREE, NICHIA, XICATO, AND SAMSUNG ARE ACCEPTABLE LED MANUFACTURERS. G.. PROVIDE LED LUMINAIRES WITH MINIMUM 5-YEAR WARRANTY AND INTEGRAL SURGE PROTECTION. LED MODULES, DRIVERS, AND POWER SUPPLIES SHALL BE FIELD-REPLACEABLE.


LUMINAIRE SCHEDULE REMARKS:

- 1. LITHONIA, COLUMBIA, DAY-BRITE, H.E. WILLIAMS, AND METALUX ARE ACCEPTABLE MANUFACTURERS FOR LUMINAIRE TYPE INDICATED.
- 2. VERIFY EXISTING VOLTAGE SERVING EXISTING LIGHTING IN EXISTING BUILDING PRIOR TO ORDERING.



SMOKE DAMPER CONNECTION DETAIL NO SCALE





OP?

─ DESIGNED BY:
─ BEL DRAWN BY: — BEL CHECKED BY: -**EMN** – DATE: — 12/29/2023

— PROJECT NO: -232051

 $oldsymbol{---}$ SHEET TITLE $oldsymbol{--}$ **ELECTRICAL** SCHEDULES

<u> SHEET NO</u> —